

E62

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. F-6/DFS/MS/2022/SZ/CH/763

Dated 09/09/2022

To

The Addl. Commissioner of Police  
Lic/Branch, 1<sup>st</sup> floor, Police Station  
Defence Colony, New Delhi.

Sub: - Regarding issuance of fire safety certificate in r/o M/s Hotel Ramhan situated at A-125, N.H- 8, Mahipalpur, New Delhi-110037.


Sir,

This has reference to your MHA Portal ID No. 2022072915433 Dated: 29.07.2022 on the subject cited above. In this connection this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 31.08.2022 in the presence of Sh. Manoj Kumar, Manager to verify the fire safety arrangements as stipulated in NBC Part 4 and as well installed in the building. During the course of inspection, the following shortcoming observed were noticed:-

1. Fire check doors not provided at the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully



**(SUNIL CHAUDHARY)**  
**DY. CHIEF FIRE OFFICER**



Copy to:

1. M/s Hotel Ramhan situated at A-125, N.H- 8, Mahipalpur, New Delhi-110037.