

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. E.6/DFS/MS/GH/2022/SZ/ 768
To

Dated: 09.09.2022

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Hotel Saptagiri at L-322, Mahipalpur, New Delhi-110037

Sir,

This has reference with **MHA Portal 2022072014896 dated 27-07-2022** on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29.08.2022 in the presence of Mr. Samser (Manager). Accordingly fire safety arrangement were tested / checked and found following observation.

1. Fire check doors not provided in the building as per clause 7.31 of UBBL 2016.
2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016.
3. First Aid hose reel not working.
4. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.
5. MOEFA Not working.
6. Automatic Sprinkler system not working.
7. Terrace level fire fighting pumps are not working.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to:-

1. M/s Hotel Saptagiri at L-322, Mahipalpur, New Delhi-110037