

C14

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/School/2022/ 563

Dated 14/09/2022

To,  
The Principal,  
M.C.D. Co-Edu. School,  
Chander Shekher Azad Colony,  
Kishan Ganj, Delhi – 110007.

**Sub: Regarding Renewal of fire FSC in r/o M.C.D. Co-Edu. School, Chander Shekher Azad Colony, Kishan Ganj, Delhi – 110007.**

Sir,

This has reference to your letter No. Nil Dated 27/07/2022 on the subject cited above, it is to inform you that the site was inspected by the officer concerned of this department on 30/08/2022 in the presence of Smt. Geeta (Principal) and the following shortcomings were observed:-

1. The width of main staircase is 1.35meter against the requirements of 1.5 meter. Hence, the width of one staircase is required to be increased 1.35 to 1.50 meter.
2. Overhead water tank capacity of 6600 liter provided against the requirements of 10,000 liter.
3. Terrace pump not in auto start provision.

Hence, FSC cannot be issued at this stage. Therefore, you are requested to rectify the above shortcomings at earliest for further consideration in the matter.

Yours faithfully

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Director (Education), Govt. of NCT, Old Sectt. Delhi - 54.