

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/2022/School/ 556

Dated: 09/09/2022

To,

The Principal,
Nigam Pratibha Balika Vidyalaya,
Nithari No.2-I, Delhi -86.

Sub: Issuance of Fire Safety Certificate in r/o Nigam Pratibha Balika Vidyalaya, Nithari No.2-I, Delhi -86.

Sir,

This is in reference to your letter No. Nil dated 26.07.2022 received through outdoor diary no. 3810 dated 27.07.2022 on the subject cited above. In this connection submitted the school was visited by officer on dated 30.08.2022 however, it has been observed that the shortcoming already issued by this department letter of even No. 160 & 3975 dated 23.01.2015 & 08.07.2019 (Copy enclosed). Therefore, you are advised to submit point-wise compliance of shortcomings issued vide this department letter dated 23.01.2015 & 08.07.2019 for further consideration in this matter.

Yours Faithfully

(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

etc
m

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

C16

No.

F6/DFS/MS/2019/School/3975

Dated:

08/07/19

To,

Principal,
Nigam Pratibha Balika Vidyalaya,
Nithari No.2-I, New Delhi-110086.

Subject: Issuance of Fire Safety Certificate to Nigam Pratibha Balika Vidyalaya (ID-1355423),
Nithari No.2 - I & II, New Delhi-110086.


Sir,

Please refer to your letter No. Nil dated 17/05/2019 on the subject noted above. In this connection it is to inform you that the said premise was inspected by the team of officer on 02/07/2019 in presence of Sh. Sunil Yadav. During the inspection it is observed the shortcomings communicated vide letter No. F6/DFS/MS/2018/School/1668 dated 25/04/2018 still not complied.

In view of above NOC /FSC cannot be considered at this stage.

You are requested to comply the above mentioned shortcomings immediately under intimation to this department for further necessary action.

Yours faithfully,


(DHARAMPAL BHARDWAJ)
DY. CHIEF FIRE OFFICER.

Ok 02

AI

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

NO. *FG/DFS/ms/school/2015/160*

Dated: *23/01* /2015

To

The Principal,
Nigam Pratibha Balika Vidyalaya
No-2 (1), Nithari, Delhi-110086

Sub: - Regarding Fire safety Certificate Nigam Pratibha Balika Vidyalaya No-2 (1), Nithari, Delhi-110086

Sir,

Please refer to your letter No- nil dated 17/12/2013 on the subject noted above. In this connection, this is to inform you that the inspection of the above said premises was carried out by the officer concerned of this department along with **Sh. Sube Singh (Principal)** on **01/11/2014** from fire safety point of view and following shortcomings were observed:

1. The width of staircase in Ground + Two upper floor block is 140 cm against required width of 150 cm. The width of staircase may be increased to 150cm or an additional staircase of 0.75 cm to be provided.
2. 07 no's of fire extinguishers provided against the required 09 no's of ABC type of 2.5 kg each
3. Terrace pump of 450 LPM not provided.
4. Overhead water storage tank of 10,000 ltr not provided.
5. ELCB at electric circuit not provided.
6. Electric meter board is below Staircase & need to be protected with metallic box or be shifted away from staircase

Keeping in view of above fire safety certificate cannot be considered at this stage.

Yours faithfully

V
20/11
(VIPIN KENTAL)
Dy Chief Fire Officer
Ph: 011-23846352

o/c t