



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2022/NDZ/ 560

Dated: 12/09/2022

To,

The Principal,
Sarvodaya Kanya Vidyalaya,
Anand Vihar,
Delhi 110092

Sub:- Regarding Issuance Fire Safety Certificate r/o Sarvodaya Kanya Vidyalaya, Anand Vihar, Delhi 110092.

Sir,

This is in reference to your letter No. SKV/AV/761 Dated 02/07/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 26/08/2022 in presence of Mrs. Alka Gogia, Principal of the School. The following points / shortcomings were noticed in the building which is comprised of ground plus three upper floors.

1. First-Aid hose reels provided but not functional.
2. Fire pump having 450 LPM output with 40 meter head provided but not functional.

In view of above, the building can not be considered for grant of fire safety certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully


(S.K. DUA)

DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

ok

Copy to:-

The Dy. Director of Education,
D-Block Anand Vihar, Delhi-110092