



No. F6/DFS/MS/GH/SZ/2022 /717

Dated: 30/8/22

To

The Joint Commissioner of Police (Licensing),  
1<sup>st</sup> Floor, Police Station Defence Colony,  
New Delhi.

Ref: Online Application no. 2022060512097

Sub: Regarding Validation of Fire Safety Certificate in r/o **M/s The Amber Guest House (Datar Reality and Hospitality Pvt. Ltd) located at 198, Sukhdev Vihar, New Delhi-25.**

Sir,

With reference to the online application no. 2022060512097 dated 05.06.2022 on the subject cited above, it is informed that the said guest house was re-inspected by the ADO, M. Road on 12.08.2022 in the presence of Mr. Gagandeep Narang, Owner and it was observed that other applicable requirements of clause 7.31, UBBL 2016 were found provided, some shortcomings listed below were observed at the time of inspection:

1. Hose reels found non functional.
2. Fire pumps found non functional.
3. Poly vinyl sheet at terrace should be removed.

In view of the existing shortcomings, the FSC issued vide letter no. F6/DFS/MS/GH/2022/SZ/103 dated 15.02.2022 stands suspended and application no. 2022060512097 stands rejected.

Yours faithfully

(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

**Copy to:**

1. The Licensee, M/s The Amber Guest House (Datar Reality and Hospitality Pvt. Ltd) located at 198, Sukhdev Vihar, New Delhi-25.