



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7/5  
आजादी का  
अमृत महोत्सव

No.F6/DFS/MS/School/SZ/2022/ 571

Dated: 14/09/2022

To

The Principal,  
Anglo Indian Public School  
B-330, Mansukh Singh Chouhan Marg,  
Sarita Vihar, New Delhi-110044.

Sub:- Regarding issuance of Fire Safety Certificate in respect of Anglo Indian Public School located at B-330, Mansukh Singh Chouhan Marg, Sarita Vihar, New Delhi-110044.

Sir,

With reference to your letter no. AIPS/3/CFO/22/7 dated 19.07.2022 on the subject cited above, it is informed that the school building was inspected by Assistant Divisional Officer (M. Road) from this department on 24.08.2022 in the presence of Mrs. Neena Khara (Principal) and it was observed that the school building is comprised of Ground + 2 upper floors. During the inspection following shortcomings was observed:-

1. No Staircase should pass/land through/ in an occupied area.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the school management. The Authority/Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Dy. Director of Education, GNCT of New Delhi DISST. South Block-C, Defence Colony, New Delhi-24.