

GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE **NEW DELHI- 110001**

F.6/DFS/MS/GH/2022/SZ/ 778 No.

Dated: 13.1.09.12022

To

The Joint Commissioner of Police, Lic/Branch, 1st Floor, P.S Defence Colony New Delhi 110049.

Sub:

Issuance of FSC in r/o M/s Hotel Shanti Palace, A-67, Mahipalpur, National Highway-8,

New Delhi-110037.

Sir.

This has reference with MHA Portal ID 2022061312694 dated 20-08-2022 on the subject cited above. In this connection, it is inform you that the premises have been inspected by officer concerned of this department on 31.08.2022 in the presence of Mr. Uday (AGM) of the Hotel. During the inspection, it was observed that the 2 Tier Basement, Ground plus four upper floor but 4th floor is sealed by SDMC. The shortcomings observed are as below:

- 1. Fire check doors not provided at the building as per clause 7.31 of UBBL 2016.
- 2. Smoke management system not provided in the building as per clause 7.31 of UBBL-2016
- 3. Carbon Monoxide detector not provided as per clause 7.31 of UBBL 2016.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(SUNIL CHAWDHARY) DY. CHIEF FIRE OFFICER (SZ)

0)~

Copy to:-

1. M/s Hotel Shanti Palace, A-67, Mahipalpur, National Highway-8, New Delhi-110037.