

E11

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/2022/572

Dated: 14/09/2022

To

The Principal,  
M.C. Primary School,  
Nuv Katra Chajju Pandit,  
New Delhi-110005.

**Sub:** Regarding Renewal of FSC in r/o **M.C. Primary School**, located at Nuv Katra Chajju Pandit, New Delhi-110005.


Sir,

This has reference to your letter no. nil dated nil, received vide DFS diary no. 3919 dated 29/07/2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 06.09.2022 in the presence of **Sh. Munna Lal** and the following shortcomings were observed:

1. Pump not in auto start mode provision.
2. Overhead tank is of 5000 liter, against requirement of 10,000 liter.

In view of above, fire safety certificate (FSC) cannot be renewed/issued.

Yours faithfully



(S.K Dua)

Dy. Chief Fire Officer  
Delhi Fire Service



Copy to:-

The Director (Education),  
Govt. of NCT, Old Sectt.  
Delhi - 54.