

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

G-43

NO. F-6/DFS/MS/School/2022/WZ/ 575

Dated: 15/09/2022

To,

The Principal,
Ravi Shankar Govt. Sarvodaya Kanya Vidyalaya,
Bawana, Delhi-110039.

Sub: - Regarding renewal of Fire Safety Certificate in r/o Ravi Shankar Govt. Sarvodaya Kanya Vidyalaya, Bawana, Delhi-110039.


Madam,

This has reference to your application no. RSGSKV/BWN/2022 received via outdoor diary no. 4352 of this department dated 12.08.2022, on the subject cited above, it is to inform you that above mentioned School building was visited by officer concerned of this department on 30.08.2022 in the presence of Smt. Bimla Devi (In-charge) to verify the compliance of the requisite fire safety measures. The school building comprised of Two Blocks Ground + First Floor & Ground + Two Upper Floors.

Your request of renewal of FSC is rejected as the following shortcoming was observed:-

1. Continuous staircase to terrace found not provided.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

eler

Copy to:-

1. The Director, Education, Govt. of NCT of Delhi, Old Secretariat, Delhi-54.