



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

7. 19/9/22
अग्नि महोत्सव

No. F6/DFS/MS/2022/WZ/ *School/574*

Dated: *15/09/2022*

To,

The Principal,
Richmondd Global School,
NS Road, Mianwali Nagar,
Paschim Vihar, New Delhi-110087.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Richmondd Global School, NS Road, Mianwali Nagar, Paschim Vihar, New Delhi-110087.

Sir,

This has reference to your email dated 14.07.2022 on the subject cited above. In this connection, it is to inform you that the said school building was re-inspected by the officer concerned of this department on 25.08.2022 in the presence of Sh. Jai Bhagwan Dagar (Caretaker).

During the inspection, it was observed that the building is comprised of Ground + 03 Upper Floors. Fire Safety arrangements such as fire extinguishers, first aid hose reel, exit signages & Overhead water storage tank etc found provided. However, the following shortcomings were observed:-

1. First Aid hose reel at ground floor found blocked with plants & wooden racks.
2. One Fire Pump found removed.
3. Overhead water storage tank found domestic connection. Overhead water tank should be exclusively for fire-fighting purpose.
4. One staircase at terrace floor found blocked/sealed & alternate staircase found sealed with plywood & waste materials.
5. Exit signages are inadequate.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit.

Yours faithfully,

[Signature]
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi - 110054

[Signature]
13/09/22

4/09/22
INTA
Lambn