

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI -110001**

F6/DFS/MS/2022/ 2049

Dated:- 1.2/08/2022

To,

Ms. Richa Choudhary,  
Estate Officer,  
Tolstoy House Welfare Association,  
Tolstoy House, 15-17, Tolstoy Marg, New Delhi.

Sub:-Regarding renewal of FSC in r/o Tolstoy House, Plot No. 15-17, Tolstoy Marg, Connaught Place, New Delhi.

Sir,

This has reference to your letter no. Nil dated 11/07/22 on the subject noted above. In this regard, it is to inform you that the site was inspected by the officers concerned of this department on 1/08/2022 in the presence of your self and the following shortcomings were observed:-

1. Fire check doors found removed from the main staircase at some floors.
2. Openings/Shafts are not sealed at floor levels properly.
3. Smoke detectors are not provided in some offices and heat detectors provided in some offices found non functional and also not connected detection panel at fire control room.
4. Lift lobby is being used as reception at some floors and the same be removed Immediately.

In view of above, application for renewal of FSC is rejected. Therefore, you are requested to rectify the above shortcomings at the earliest under intimation to this department. Further, the occupancy of building /premises in absence requisite fire & life safety arrangements shall be at the risk and liability of the owner/occupier. The statutory/licensing authority may take suitable action as deemed fit.

Yours faithfully,

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.