

1-8
1-9

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/WZ/2022/ 52

Dated: 15/9/22

To,

The Principal,
M. D. Indraprastha Institute for Higher Education,
Plot No.41-42, Khasra No.2/24, Rajeev Nagar, Begumpur Ext.
Delhi-86.

Sub: Issue of FSC in r/o M. D. Indraprastha Institute for Higher Education, Plot No.41-42, Khasra No.2/24, Rajeev Nagar, Begumpur Ext. Delhi-86.

Sir,

Kindly reference to online e-mail dated 10.08.2022, received in this department on the subject cited above. The premise was inspected by the concern nominated authority of this department on **06.09.2022**, in presence of **Dr. Sarwati (Principal)** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. 03 fire extinguishers of ABC type provided against the required 06 no's of ABC / Co2 type 2.5 kg capacity required to be provided.
2. First Aid hose reel not provided.
3. Terrace Fire pump with capacity 450 LPM not provided.
4. 10,000 ltrs Over Head water captive tank not provided.
5. The required exit signage are not provided.

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:
http://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/htt
p://www.delhi.gov.in/wps/wcm/connect/doi_t_fire/FIRE/Home/Forms

Yours faithfully


(Dhrampal Bhardwaj)
Dy.Chief Fire Officer
Tel;-01123414250

otc
my