

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI – 110001

NO. F6/DFS/MS/CGHS/SZ/2022/ 2335

DATED: 19/09/2022

To,

Sh. Sunil Sharma (Secretary),  
Great Capital CGHS Ltd  
Plot No – 15, Sector – 06,  
Dwarka, New Delhi.

Subject: - Renewal of Fire Safety Certificate in r/o Great Capital CGHS Ltd. Located at Plot No – 15, Sector – 06, Dwarka, New Delhi.

Sir,

Please refer to your Email dated-29/08/2022 on the subject cited above. In this connection it is to inform to you that the above said residential building has been inspected by the officer concerned of this department on 02/09/2022 in presence of Sh. Sunil Sharma (Secretary) for fire safety point of view.

During the course of inspection followings shortcoming have been observed:-

1. Internal road around the building found encroached / blocked.
2. Only one fire extinguisher of ABC type 4 kg capacity found provided against required two extinguishers at each floor.
3. Hose Reels & Hydrants found nonfunctional.
4. Yard Hydrants found removed.
5. Terrace Pumps found nonfunctional in auto mode.
6. Terrace tank of capacity 10,000 ltr found empty.
7. Communication system in lift found nonfunctional

You are requested to comply the abovementioned shortcomings under intimation to this department.

In view of the above shortcomings Fire Safety Certificate cannot be considered at this stage.

Yours faithfully,

  
(Atul Garg)  
(Director)  
Delhi Fire Service

Copy to:-1. The Joint Director, DDA, Vikas Sadan, INA, New Delhi.