

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No.F6/DFS/MS/NDZ/2022/44/797

Dated:-16.09/2022

To

The Manager  
M/S Kabana Guest House,  
1022-1024/18, Arya Samaj Road,  
Karol Bagh, New Delhi.

Sub: Regarding issuance of FSC in r/o M/S Kabana Guest House, located at 1022-1024/18, Arya Samaj Road, Karol Bagh, New Delhi.


Sir,

This has reference to Online id no. 2022081916352 dated 21/08/2022, on the subject cited above. In this connection it is to inform you that the site was inspected by the officer concerned of this department on 07/09/2022 in the presence of **Manager** and following shortcomings were observed:-

1. Smoke management system is required to be provided upto 30.09.2022 as per gazette notification dated 27.05.2019.
2. CO detectors are required to be provided upto 30.09.2022 as per gazette notification dated 27.05.2019.
3. Hose reel found nonfunctional.
4. Pump not in auto mode start provision.

In view of above, Fire Safety Certificate cannot be issued. Therefore, you are requested to rectify the shortcomings for further consideration in the matter.

Yours faithfully,

  
(S.K. Dua)

Dy. Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi.