

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/2022/SZ/ 2351
To

Dated: 15/09/2022

Mr. Gaurav Kumar Meena,
M/s NBCC Plaza
(Community Centre cum Commercial Complex),
Pushp Vihar, Sect-V, New Delhi-110017

Sub: Issuance of NOC in r/o M/s NBCC Plaza (Community Centre cum Commercial Complex),
Pushp Vihar, Sect-V, New Delhi-110017

Sir,

This has reference to your letter no nil dated 12/07/2022 received through outdoor diary no 3252 dated 12/07/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29.08.2022 in the presence of Mr. Kuldeep Soni to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Ventilation system not on auto mode.
2. Automatic fire detection & alarming system provided but non functional.
3. The MOEFA system is provided but non functional.
4. The Sprinkler provided but non functional.
5. The Internal Hydrant provided but non functional.
6. Fire fighting pumps are not on auto mode.
7. Pressurization of lift lobby not functional.
8. There is a electrical Panel Board installed at ground floor lift lobby. Which need to be removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,


(ATUL GARG)
DIRECTOR

Copy to:-

1. The Executive Engineer (Bldg) South Zone, Green Park, Aurobindo Marg, New Delhi 110016.