

224

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/School/2022/ 591

Dated 21 / 09 / 2022

To

The Principal
Bhai Mandeep Nagpal Nigam Vidyalaya,
Aruna Nagar-II, Delhi-110054.

Sub: Regarding issuance of fire safety certificate in r/o Bhai Mandeep Nagpal Nigam Vidyalaya located at Aruna Nagar-II, Delhi-110054.


Sir,

Please refer to your letter no. Nil dated 16.08.2022 and received in this office vide outdoor dairy no.4434 dated 17.08.2022 on the subject cited above. In this connection this is to inform you that the above mentioned site was visited by the officer concerned of this department on 09.09.2022. At the time of inspection Sh. Raj Kumar (Incharge) was also present at site to verify the fire safety measures issued Director of Education Circular dated 01.03.2011 and observed that the building was comprised of ground & Two Upper Floors Only. During the course of inspection observations/ shortcomings made are as under:-

- 1 Fire extinguisher provided in the building were checked and found not working at the time of inspection.
- 2 Hose reel hose provided but not functional and hose reel damaged/leakage condition. Some nozzle is missing.
- 3 Terrace level fire pump capacity of 450lpm provide but not functional.
- 4 Overhead fire water tank capacity of 10,000ltrs is being used for domestic purposes. Fire water tank must be dedicated to firefighting purposes only.
- 5 Exit signage not provided at strategic locations in the building.

Keeping in view of above, fire safety certificate cannot be considered at this stage.

Yours faithfully


(Atul Garg)
Director
Ph: 011-23414000

Copy to:-

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.