

2100  
C25

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE**  
**NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/ 595  
To

Dated: 21.1.2022

The Principal,  
Bhatnagar International Foundation School,  
Plot No 7, Sector-B, Pocket- 8 & 9,  
Vasant Kunj, New Delhi 110070

Sub: Regarding issuance of FSC in r/o Bhatnagar International Foundation School, Plot No 7, Sector-B, Pocket- 8 & 9, Vasant Kunj, New Delhi 110070


Sir,

This has reference to letter received through outdoor diary no 2555 dated 17-06-2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.09.2022 in the presence of Mr. Vinod Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but not functional.
2. Terrace level Fire Pump capacity of 450 LPM provided but not functional.
3. The fire fighting tank is also being used for domestic purposes.
4. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)  
DELHI FIRE SERVICE

aw

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054