

C24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 584

Dated: 21/09/2022

To

The Principal,  
DAV Public School,  
Ashok Vihar, Phase-IV,  
New Delhi -110052.

**Subject: Regarding renewal of Fire safety Certificate in respect of M/s. DAV Public School, Ashok Vihar, Phase-IV, New Delhi -110052.**


Sir,

Please refer to your letter no. DAVPS/AV-IV/8578 dated: - 04/07/2022 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officer concerned on 05/09/2022 in the presence of Mr. Rajkumar (Estate Manager), during inspection it has been observed that the building is comprised of Two Blocks (1<sup>st</sup> Ground + 03 Upper Floors + Tin Shed at Terrace & 2<sup>nd</sup> BL- Ground Floor only). Fire Safety arrangements such as Fire Extinguisher, First-Aid Hose reel, Internal Hydrant, Over Head Tank, etc are provided. However, the following shortcomings were observed:-

1. First-Aid Hose Reels & Internal Hydrant at each floor is provided but not functional.
2. Terrace fire pump of capacity 450LPM & 180LPM is provided but not functional.
3. Exit Signage's are Found Removed at Some Places.
4. There are 06 teen shaded rooms on the terrace floor it shall be removed.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is cannot consider at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully

  
(Dharampal Bhardwaj)  
Dy. Chief Fire Officer  
West Zone

Copy To: -

1. The directorate of Education, old secretariat, Delhi.

  
15/9/2022