

C-31

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE**  
**NEW DELHI- 110001**

No: F.6/DFS/MS/School/2022/SZ/ 597

Dated: 21/09/2022

To,

The Principal,  
Golden Valley Senior Secondary Public School,  
A-161, Todarmal Colony, Najafgarh, New Delhi-110043.

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o Golden Valley Senior Secondary Public School, A-161, Todarmal Colony, Najafgarh, New Delhi-110043.

Sir,

This has reference to your letter No. GVSSPS/2022/09/1155 dated 05/09/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 09/09/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Sh. Anil Sharma (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. Fire Extinguishers ABC/Co2 type provided but not functional.
2. First Aid Hose Reel provided but not functional.
3. Fire pump having 450 LPM provided but not functional
4. Overhead tank capacity 2,000 provided in senior block instead of 10,000 ltr & 7,000 ltr provided in Junior block.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully

  
(Sunil Chawdhary)

**Dy. Chief Fire Officer**  
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.