

C8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI – 110001**

No. F6/DFS/MS/School/2022/593

Dated: 21/09/2022

To

The Principal,  
MCD Primary Co-Ed. School,  
Doriwalan KishanGanj,  
New Delhi.

**Sub: Regarding issuance of FSC in r/o MCD Primary Co-Ed. School, Doriwalan KishanGanj,  
New Delhi.**

Sir,

This has reference to your letter no. nil dated 06.09.2022 on the subject cited above. In this regard, it is to inform you that the site was inspected by officer concerned of this department on 06.09.2022 in the presence of **Ms. Rumana Parveen** and observed that the access to the building for fire vehicle/tender is less than the required width of 06 meter. Hence, fire safety certificate (FSC) cannot be issued to the said school.

Yours faithfully

  
(Abdul Garg)  
DIRECTOR  
Delhi Fire Service  


**Copy to:-**

The Director of Education,  
Govt. of NCT of Delhi, Old Sectt.  
Delhi – 54.