

C-12 FT C-12

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/587

Dated: 21/09/2022

To

The Chairman,  
MCD Pry. School, Pusa Lane,  
Padam Singh Road, Karol Bagh, New Delhi-110005.

Sub:- Regarding issuance of Fire Safety Certificate in r/o MCD Pry. School, Pusa Lane, Padam Singh Road, Karol Bagh, New Delhi-110005.

Sir,

Please refer to your letter no. nil, dated 16.08.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Smt. Poonam Shabarwal (Principle), on 08.09.2022 to check the status of the shortcomings pointed out by this department vide letter No. F.6/DFS/MS/2012/School/2971 dated 14.08.2012, but no improvement was observed as seen during the course of inspection and this department has already issued a letter in this matter vide this office letter No. F.6/DFS/MS/School/2020/203 dated 07.04.2020.

In view of the above, 'Fire Safety Certificate' cannot be consider at this stage. You are requested to rectify the above-mentioned fire safety arrangements under intimation to this department.

Yours faithfully

(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service

Copy to: -

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.  
(with a request to take further action as school does not have fire NOC)

C-2

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110 001**

No. F.6/DFS/MS/2011 *school/2971*

Dated *14/08/12*

To

The Principal,  
M.C. Primary School,  
Pusa Lane, Padam Singh Road, Karol Bagh,  
New Delhi - 110005.

Sub: Issuance of NOC in r/o M.C. Primary School, Pusa Lane, Padam Singh Road, Karol Bagh,  
New Delhi - 110005.

Madam,

Please refer to your office letter No: Nil dated 11.07.2012 on the subject cited above. In this regard it is to inform you that the above said premises was inspected by the officer concerned of this department on 09.08.2012 from fire safety point of view. Smt. Mamta Sethi, Incharge was present at the time of inspection.

During the course of inspection it was observed that the building is located in a motor able road and easily approachable to the fire engine. The school building comprised of ground plus one upper floor and served by single staircase having width of 1.25 cms. but the building does not meet the required norms as per the Director of Education letter No. F.16/Estate/CC/Fire safety/2011/3298 to 3398 dated 01.03.2011 due to the following shortcomings:

1. Some portable fire extinguishers were provided which are not adequate. One Co2 type 4.5 kg cap & one ABC type 5 kg cap fire extinguishers shall be provided at each floor of the building.
2. The staircase width is 125 cms instead of 1.50 mtrs.

In view of the above no objection certificate cannot be considered at this stage. The Management is directed to rectify the above-mentioned shortcomings and intimate to this department.

Yours faithfully

*[Signature]*  
13/8  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Director of Education  
MCD Nigam Bhawan (Old Hindu College Bldg.)  
Kashmere Gate, Delhi
2. Divisional Officer ( SW ) Shanker Road