

C-38

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/School/592

Dated: 21/09/2022

To,
The Principal,
MCD Primary School (Girls),
Village Pochanpur, Sector - 23,
Dwarka, New Delhi - 110075.

Subject: Issuance of Fire Safety Certificate in r/o MCD Primary School (Girls) Located at Village Pochanpur, Sector - 23, Dwarka, New Delhi - 110075.

Sir,

Please refer to your letter No Nil dated-16/08/2022 on the subject mentioned above. In this connection it is to inform you that the premises was visited by the officer concerned from this department on 03/09/2022 in the presence of Ms. Neela anil (In charge) and found that newly constructed block is comprised of Ground + 03 upper floors. The ground & 1st floor are meant for classroom, however, the double height badminton court is constructed at 2nd floor and a visitor gallery is given at 3rd floor. Hence it is a mixed occupancy.

In view of above you are requested to submit the two set of building plans in the ratio of 1:100, duly marked with fire and life safety measures provided in the building though concern building sanctioning authority

Yours faithfully,

(Atul Garg)
Director
Delhi Fire Service

ok
21/9/22

Copy to:-

1. Directorate of Education Old Secretariat Delhi - 110054.