

C-15

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 596

Dated: 21/09/2022

To,

The Principal,
SDMC Primary School, Uttam Nagar New No.-I/II,
K-Block, Santosh Park, Uttam Nagar, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o SDMC Primary School, Uttam Nagar New No.-I/II, K-Block, Santosh Park, Uttam Nagar, New Delhi-110059.


Sir,

This has reference to your letter No. Nil dated 22/07/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 06/09/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Manju (Principal) was present and it was observed that the school building is comprised of ground plus two upper floors and have following shortcomings.

1. First Aid Hose Reel provided but not functional.
2. Fire pump having 450 LPM provided but not functional

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully



(Sunil Chawdhary)

Dy. Chief Fire Officer

Delhi Fire Service



Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.