

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/ 603

Dated: - 22/09/2022

To,

The Assistant Engineer (E),
 Sub-Div- 1 Education Division M 1 (N),
 PWD GNCT, Govt. of Delhi, ITI Campus, Pusa Road, New Delhi- 110012.

Sub.- Regarding renewal of Fire Safety Certificate in r/o Govt. Boys Sr. Sec. School, West Patel Nagar, New Delhi- 110008.

Sir,

Please refer to your letter No. 54(SPS School)/PWD Edu.Sub-Divn M1-1(N)/2021-22/Camp01 dated 10.08.2022, on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department in presence of Sh. Suresh Chand Gupta (Fire Supervisor) on 02.09.2022 to check the functionality of the existing fire safety arrangements in the school building.

During inspection, it has been observed that the said school building was having four blocks namely Block A, B, C & block D, each block are comprised of ground plus three upper. Block A, B & C are interconnected and block D is separate. Fire safety arrangements such as hose reel, terrace pump, overhead water tank, fire extinguishers, exit signage etc. found provided in the school building. However, the following shortcomings were observed:-

1. At block 'D' having one staircase width of 1.75 mts is provided against the requirement of two staircase having width of 1.50 mts each.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be issued at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department.

Yours faithfully,


 (Atul Singh)
 Director

Delhi Fire Service

Copy to: -

1. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, Delhi
for information please
2. The Principal, Govt. Boys Sr. Sec. School, West Patel Nagar, New Delhi- 110008.