

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/GH/2022/SZ/ 803
To

Dated: 21.09.2022

The Addl. Commissioner of Police,
Lic/Branch, 1st Floor, P.S Defence Colony
New Delhi 110049.

Sub: Regarding issuance of FSC in r/o M/s Shyama International located at C-5/32, Safdarjung development Area, New Delhi- 110029.


Sir,

This has reference with MHA Portal ID 2022080215662 dated 02/08/2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 13.09.2022 in the presence of Mr. Nitesh Kumar (Account) of the Guest House. During the inspection, it was observed that the Guest House is running Ground plus Three Upper Floors. The shortcomings observed are as below:

1. MOEFA found removed.
2. Fire Fighting pump not on auto mode.
3. Further, it is requested to comply the fire safety provisions under clause 7.31 of UBBL- 2016 in the building, in compliance with the notification of dated 27/05/2019 and as approved and further extended the deadline/ time limit by the Directorate of Local Bodies, UDD, GNCT of Delhi vide their letter no. F5 (189)/AD/LB/2016/5514-31 dated 31.05.2022 for compliance on or before 30/09/2022.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to:-

1.M/s Shyama International located at C-5/32, Safdarjung development Area, New Delhi- 110016