

C-70

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/EH/NDZ/2022/ 813

Dated: 23/09/2022

To

The Manager,
M/s Kuldeep Lodge,
Plot no. 279, General Market,
Pahar Ganj, New Delhi.

Sub: Regarding grant of FSC in r/o M/S Kuldeep Lodge, Plot no. 279, General Market, Pahar Ganj, New Delhi.


Sir,

This has a reference to online ID No. 2021091921919 dated 29.09.21 & e-mail <brijk943@gmail.com> dated 11.09.2022 on the subject cited above. In this connection, it is to inform you that the site was visited by the officer concerned of this department on dated 16.09.22 in presence of **Manager** and following shortcomings were observed: -

- 1) First aid hose reel found nonfunctional.
- 2) PA system found non functional.
- 3) The no. of rooms as mentioned in online performa does not match with the building plan as uploaded.

Hence, Fire Safety Certificate (FSC) cannot be issued at this stage. Therefore, you are requested to submit the compliance of the shortcoming for further consideration in the matter.

Yours faithfully


(S.K. Dua)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

The Addl. Commissioner of Police (Lic.), Licensing Unit, Defence Colony Police Station, New Delhi.