



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 606

Dated: 23/9/22

To

The Principal,
North Delhi Primary Model School,
Karampura G-Block,
New Delhi -110015.

Subject: Regarding issuance of Fire safety Certificate in respect of M/s. North Delhi Primary Model School, G- Block, New Delhi – 110015.

Sir,

Please refer to your letter dated 30/07/2022 on the subject cited above. In this connection, it is to inform you that the said building was re inspected by the officer concerned on 02/09/2022 in the presence of Smt. Roopvati (Principal), during inspection it has been observed that the building is comprised of Ground + 03 Upper Floors. Fire Safety arrangements such as Fire Extinguisher, First-Aid Hose reel, Exit signages, Over Head Tank, etc are provided. However, the following shortcomings were observed:-

1. First-Aid Hose Reels at each floor are provided but not functional.
2. Terrace fire pump of capacity 450 LPM capacity on terrace is provided but not functional.

In view of above Shortcomings the application for Issuance of Fire safety Certificate is cannot consider at this stage & rejected. The occupancy of the Building/ premises in absence of requisites fire safety measures shall be at the risk and liabilities of the owner/occupier. Statutory authority may take suitable necessary action as deemed fit.

Yours Faithfully


(Atul Garg)
Director
Delhi Fire Service

Copy To: -

1. The directorate of Education, old secretariat, Delhi.

o/c
SPP
21/9/22