

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI – 110001**

F6/DFS/MS/2022/NDZ/ 2412

Dated:- 21/09/2022

To,

The Executive Engineer,  
Delhi High Court Civil Division (M-431) PWD,  
Gate No- 6, Jawahar Lal Nehru Stadium, New Delhi -03.

**Sub:- Regarding issuance of Fire Safety Certificate in r/o S- block, at Delhi High Court, Zakir Hussain Marg, New Delhi.**

Sir,

This has reference to your letter no. 34( S- Block) EE/Delhi High court / PWD/581 dated 09.09.2022 on the subject cited above. In this regard, it is to inform that the site was inspected by the officers concerned of this department on 15/09/22 in the presence of Sh. Y.P.S Sharma AE (E), Sh. Manoj Bhaskar, AE (C) & Sh. M.C.Gupta EE(E) and the following shortcomings were observed:-

1. 06 meter road for fire tender movement all around each block is not provided as per approved building plan. Further, trimming of trees are required at the entrance gate to enter the fire vehicle easily.
2. Fire check doors are not provided at service lift lobby & the width of 02 no. of door auditorium is required to be extended to 02 meter wide.
3. The width of fire check door is not provided equal to the width of staircase in ancillary block.
4. Electric shafts/openings are not sealed properly.
5. Detectors & sprinklers are required to extend in left out area.
6. Pressurization of service lift lobby & at 8<sup>th</sup> floor is not provided.

In view above shortcomings, the case is rejected with a request to rectify the above shortcomings and inform to this department for further consideration in the matter.

Yours faithfully



(Atul Garg)

**DIRECTOR**

Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi – 110001.
2. The Chief Engineer (other project) 13<sup>th</sup> floor, MSO building, New Delhi.
3. The Registrar (General Admn.), High Court, New Delhi.