



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/WZ/EH/2022/581

Dated: 21/09/2022

To,

The Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor,  
Police Station, Defence Colony,  
New Delhi.  
[addlcp.lic-dl@nic.in](mailto:addlcp.lic-dl@nic.in)

**Subject: Issuance of Fire Safety Certificate in respect M/s. So Chow (A unit of Moon Peak Hospitality Pvt. Ltd.) Located at A-6, 3<sup>rd</sup> Floor, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi-110027.**

Sir,

Please refer to your application no. 2022042608414 dated 29/07/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises was re-inspected by the officer concerned of this department on 31/08/2022 in the presence of Sh. Mohit Sardana and observed that the shortcomings already communicated by this department vide letter F6/DFS/MS/EH/WZ/2022/474 dated 14/07/2022, is still not complied.

In view of above, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi-110027.  
Email Id : - ([dhowest\\_zone@gmail.com](mailto:dhowest_zone@gmail.com))
2. The Owner/Occupier M/s. So Chow (A Unit of Moon Peak Hospitality Pvt. Ltd.)  
Located at A-6, 3<sup>rd</sup> Floor, Main Najafghar Road, Vishal Enclave, Rajouri Garden,  
New Delhi -110027.

AP  
19/9/22

C 29

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE**

No. F6/DFS/MS/EH/WZ/2022/ 474

Dated: 14/07/2022

To,

Joint Commissioner of Police,  
Licensing Unit, 1<sup>st</sup> floor,  
Police Station, Defence Colony, New Delhi.  
E-Mail - [Addcp.lic@delhipolice.gov.in](mailto:Addcp.lic@delhipolice.gov.in).

**Sub: - Issuance of Fire Safety Certificate in respect M/s. So Chow (A unit of Moon Peak Hospitality Pvt. Ltd.) Located at A-6, 3<sup>rd</sup> Floor, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi-110027.**

Sir,

Please refer to your online application no.- 2022042608414 dated 17/05/2022 received through MHA portal, on the subject cited above. In this connection, it is to inform you that the premises was inspected by officer concerned of this department on 13/06/2022 in the presence of Sh. Jatin Singh to check the shortcoming already issued by this department vide letter No. F6/DFS/MS/MN/2022/EH/264 dated 23/03/2022.

The Status of shortcomings are as under:-

S.N.	Shortcomings	Status
1.	Width of Stair is 1 x 152 cm & 1 x 170 cm iron staircase is blocked.	Rectified
2.	Width of door size is 1 x 113 cm & 1 x 153cm provided instead of 1.5 mtr each.	Rectified
3.	Main fire pump of 2280 lpm, Jockey pump 180 lpm, and stand by pump 2280 lpm are not provided.	Provided but not functional
4.	Underground Water Storage tank of capacity 1, 00,000 ltrs is not provided.	Overhead tank is provided but found empty
5.	Exit Signage's are not provided.	Rectified

In view of above Shortcomings, the application for Issuance of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The licensing issuing authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

  
(With Care)  
Director  
Delhi Fire Service

Copy to: -

1. The Owner/ Occupier M/s. So Chow (A unit of Moon Peak Hospitality Pvt. Ltd.) Located at A-6, 3<sup>rd</sup> Floor, Main Najafgarh Road, Vishal Enclave, Rajouri Garden, New Delhi-110027.
  2. DHO, West Zone, SDMC, Shivaji Enclave, Raja Garden, New Delhi- 110027.  
([dhowest\\_zone@gmail.com](mailto:dhowest_zone@gmail.com))
- SAP  
12/7/2022