

C-34

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110001

No: F.6/DFS/MS/School/2022/SZ/ 609

Dated: 27/9/22

To,

The Principal,
Angel Public School, WZ-2, Phase-II,
Om Vihar, Uttam Nagar, New Delhi-110059.

Sub: - Regarding issuance of Fire Safety Certificate in r/o Angel Public School, WZ-2, Phase-II,
Om Vihar, Uttam Nagar, New Delhi-110059.


Sir,

This has reference to your letter No. Renewal letter/2022 dated 31/08/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 15/09/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Neelam Sharma (Principal) was present and it was observed that the school building is comprised of ground plus three upper floors and have following shortcomings.

1. First Aid Hose Reel provided but not functional.
2. Fire pump having 450 LPM provided but not functional
3. Exit Signage's provided but not sufficient.

In view of above, the fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully


(Sunil Chawdhary)

Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Director of Education, Govt of NCT of Delhi, Old Secretariat, New Delhi-110054.