



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001**

No.F.6/DFS/MS/Hospital/2022/NDZ/ 2343/2443

Dated: 23/9/2022

To,

The Medical Superintendent,  
Goyal Hospital & Urology Centre  
E-4/5 & 4/6, Krishna Nagar,  
Delhi 51

**Subject: -Regarding issuance of Fire Safety Certificate in r/o Goyal Hospital & Urology Centre located at E-4/5 & 4/6, Krishna Nagar, Delhi 51.**

Sir,

This is in reference to your letter No. nil dated 16/07/2022 on the subject cited above. In this connection, it is to inform you that the team of officers concerned of this department have carried out the inspection of the above mentioned hospital on dated 07/08/2022 from fire safety point of view in presence of Dr. Vipin Rastogi. During the course of inspection, following shortcomings were noticed in the building which is comprised of basement, stilt, ground plus three upper floors.

1. Two Staircases of width 1.10 meter & 2.00 meter are provided against the requirement of 1.50 meter width & 2.00 meter width.
2. Width of corridor 1.75 meter provided against the requirement of 2.40 meter in the building.
3. Fire check door not provided in the basement.
4. Smoke management system not provided in the basement.
5. Pressurization of lift lobby and lift shaft not provided.
6. Communication in lift car not provided.

In view of above, the building can not be considered for issue of Fire Safety Certificate at this stage. Therefore you are suggested to rectify the above mentioned shortcomings under the intimation to this department for further course of action.

Yours faithfully,

  
(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

Director of Health Service  
M.O. I/C Nursing Home Cell, Govt. of NCT of Delhi,  
F-17 karkardooma, Delhi -110032