

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2022/SZ/ 611
To

Dated: 27/09/2022

The Principal,
SDMC Primary Girls/Boys School,
Govindpuri Kalkaji New Delhi 110019

Sub: Issuance of FSC in r/o SDMC Primary Girls/Boys School, Govindpuri Kalkaji New Delhi
110019


Sir,

This has reference to your letter received through outdoor diary no 4456 dated 16/08/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 15.09.2022 in the presence of Mr. Akhleshwar Narayan Pathak (Principal) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First Aid Hose Reel not functional.
2. Terrace level Fire Pump capacity of 450 LPM provided not functional.
3. Overhead tank capacity 10,000 ltrs provided found removed.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE

Copy to:

1. The Directorate of Education, South MCD, Civic Centre, Minto Road, New Delhi-110002