

C-28

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2022/ 608

Dated: 27/9/2022

To,

The Principal <soe182182@gmail.com>
School of Excellence,
Sector - 22, Dwarka, New Delhi


Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o School of Excellence, (earlier known as Govt. Sr. Sec. School) Located at Sector - 22, Dwarka, New Delhi (School ID - 1821282).

Sir,

Please refer to your email dated 09/09/2022 on the subject mentioned above. In this connection it is to inform you that the above said premises was visited by the officer concerned of this department on 19/09/2022 in presence of Dr. Ritu Kumari (HOS) to see the compliance of the shortcomings communicated vide this office letter No. F6/DFS/MS/ SZ /2022/463, dated 04/08/2022 & found that the shortcomings are still not fully complied. You are requested to comply the shortcomings under intimation to this department for further consideration in the matter.

In view of the above Fire Safety Certificate from fire safety point of view cannot be considered at this stage.

Yours faithfully,


(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI – 110001**

NO. F6/DFS/MS/SZ/2022/ 463

DATED: 4 / 8 / 2022

To,

The Principal <dwarkasector22@gmail.com>
School of Excellence,
Sector – 22, Dwarka, New Delhi

Subject: - Renewal of Fire safety Certificate from fire safety & means of escape point of view in r/o School of Excellence, (earlier known as Govt. Sr. Sec. School) Located at Sector – 22, Dwarka, New Delhi (School ID – 1821282)

Sir,

Please refer to your letter no SOE/Sec-22/Dwk/2022/208, dated 02/07/2022 & Email Dated 04/07/2022 on the subject cited above. In this connection it is to inform you that the above said building has been visited by the officer concerned of this department t on 20/07/2022 in the presence of Dr. Ritu Kumari (HOS).

During the course of inspection followings shortcoming are observed

1. Hose reel hose found nonfunctional
2. Terrace pumps of 450 lpm found nonfunctional and not in auto mode
3. Exit signage's found removed at some places.

In view of the above, Fire Safety Certificate cannot be considered at this stage.

You are advised to rectify the said shortcomings under intimation to this department

Yours faithfully,



(Sunil Chaudhary)
Dy. Chief Fire Officer
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054.