

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No. F.6/DFS/MS/School/2022/SZ/ 610  
To

Dated: 27/09/2022

The Principal,  
Step By Step Nursery School,  
(Wooden Structure) Plot No 1 & 2,  
Panchsheel Park, New Delhi 110017

Sub: Regarding issuance of FSC in r/o Step By Step Nursery School, (Wooden Structure) Plot No 1 & 2, Panchsheel Park, New Delhi 110017

Sir,

This has reference to letter received through outdoor diary no 2555 dated 17-06-2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 12.09.2022 in the presence of Mr. Vinod Kumar to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. First aid hose reel provided but not functional.
2. Terrace level Fire Pump provided but not functional.
3. Exit signage found removed in some places.
4. Due to wooden structure fire resistant paints are required.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

  
(SUNIL CHAWDHARY)  
DY. CHIEF FIRE OFFICER (SZ)  
DELHI FIRE SERVICE

Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054