

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/School/2022/SZ/ 612
To

Dated: 27/09/2022

The Principal,
Suraj Bhan DAV Public School,
F-10/15, Vasant Vihar, New Delhi-110057

Sub: Regarding issuance of FSC in r/o Suraj Bhan DAV Public School, F-10/15, Vasant Vihar, New Delhi-110057


Sir,

This has reference to letter no nil dated 05/09/2022 received through outdoor diary no 5312 dated 06-09-2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 17.09.2022 in the presence of Mr. Jogender Pal (Admin) to verify the fire safety measures installed in the building. Accordingly fire safety arrangement were tested / checked and found following observation.

1. Automatic Sprinkler System provided but not functional.
2. Fire fighting Pumps are provided but not on auto mode.
3. Exit signage found removed in some places.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully,



(SUNIL CHAWDHARY)
DY. CHIEF FIRE OFFICER (SZ)
DELHI FIRE SERVICE



Copy to:-

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054