



7-
G17

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/ 614

Dated: 29/09/2022

To,

The Principal,
North Delhi Municipal Corporation Primary School,
Sri Nagar, Old-2, Keshavpuram Zone (Ward no.70),
New Delhi-110034.

Subject: Regarding Renewal of Fire Safety Certificate in r/o M/s M. C. Pvy. School
Located at, Sri Nagar, Old-II, (Keshavpuram zone), New Delhi-110034.

Sir,

Please refer to your letter outdoor diary no. 5046 dated 31/08/2022 on the subject cited above. In this connection, it is to inform you that the said building was re-inspected by the officer concerned of this department on 15/09/2022 in presence of Smt. Kiran Bala (Principal) to check the shortcomings already issued by this department vide letter no. F6/DFS/MS/2022/WZ/180 dated 18/04/2022.

The Following Shortcomings Status is:-

S. no.	Shortcomings	Status
1.	First-Aid Hose Reels found non-functional.	Not Rectified
2.	Terrace fire pump of capacity 450 LPM found non-functional.	Not Rectified
3.	Overhead water Storage tank capacity of 2,000 ltrs found damage instead of requirement 10,000 ltr.	Not Rectified
4.	06 nos ABC Type Fire Extinguisher is not provided.	Rectified

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety Arrangements Shall be at the risk and liabilities of the Owner/occupier. The authority/statutory authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully

(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy To: -

1. The Director, Directorate of Education, old secretariat, Delhi.

o/c
26/9/22