

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/WZ/2022/ School 6/6

Dated: 29/09/2022

Ms. Shipra Nijhawan, Presidium Punjabi Bagh, 11/77 West Punjabi, Delhi-110026.

Subject: -Regarding issuance of Fire Safety Certificate in r/o Presidium Punjabi Bagh (Shri Narendra Charitable Trust) Located at 11/77 West Punjabi Bagh, New Delhi-110026.

Sir,

Please refer to your email dated 21.05.2022 on the subject cited above. In this connection it is to inform you that the said school building have been inspected by the officer concerned of this department on 08.09.2022 in the presence of Sh. Vineet Kumar. During inspection, it has been observed that the school building is comprised of Basement + Ground + .03 Upper floors only served with 03 staircases. Fire Safety arrangements such as fire extinguisher, first aid hose reel, smoke management system, automatic sprinkler system, fire pumps, & overhead water tank etc found provided. However the following shortcoming has been observed:-

1. The width of staircases is 1.5 m, 1.23 m & 1.08 to 1.21 m provided against required 02 nos. staircase of 1.5 m width each.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours faithfully

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054