



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/Cinema/WZ/2022/ 2489

Dated: 30/09/2022

To

Sh. Shazad Alam, SDM (Rohini),
District North-West, Office of the Dy. Commissioner,
Govt. of NCT of Delhi, Kanjhaawala, Delhi-81.

Sub: - Regarding joint inspection report in r/o Cinepolis India Pvt. Ltd. located at Pacific Mall, Netaji Subhash Place, New Delhi.

Sir,

This is in reference to your letter for joint inspection report in r/o Cinepolis India Pvt. Ltd. located at Pacific Mall, Netaji Subhash Place, New Delhi, a joint inspection was carried by the team of Officers of different Government agencies on 26.09.2022 in presence of Sh. Hemant Uppal (manager) to check the required fire safety arrangements provided in the multiplex as per guidelines issued by this department.

During the course of inspection, it was observed that the 09 Audi's are running at third & fourth floor in a building comprised of 02 basements, lower ground, ground plus 04 upper floors. Fire safety arrangements such as underground water tank, fire check doors, fire extinguishers, hose reel, detection system, MOEFA, PA system, automatic sprinkler system, fire pump etc. already provided in the building and extended in the Audi's. However following shortcomings were observed: -

1. Automatic Sprinkler system shall be extended in left out areas.
2. Ventilation system provided in each Audi was not functional. Ventilation system was not provided in the operator less projection rooms.
3. Beam detection system was not functional in One Audi.
4. Exit signages were not illuminated.
5. PA system in each Audi was not functional.
6. Fire protection system was not provided in the LT Panel located in the back house area of Audi's.
7. Trained fire staffs are not deputed in the cinema hall. Evacuation plan is not displayed in each Audi.
8. Corridors at some places is less than the required width of 2 mts

In view of above shortcomings, the application for issuance fire safety certificate cannot be considered at this stage and rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier.

Yours Faithfully

(Atul Gang)
DIRECTOR

Copy to: -

1. The Executive Director (PD), DMRC, 25, Ashoka Road, New Delhi-110003.
2. The Manager, Cinepolis India Pvt. Ltd. located at Pacific Mall, Netaji Subhash Place, New Delhi.