



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/School/WZ/2022/624

Dated: 03/10/2022

To,

The Principal,
Govt. Co-ed Sr. Sec. School,
Narang Colony, Tri Nagar,
New Delhi – 110035.

Sub: - Regarding Renewal of Fire Safety Certificate in r/o Govt. Co-ed Sr. Sec. School
Located at Narang Colony, Tri Nagar, New Delhi – 110035.

Sir,


Please refer to your Email dated 31/08/2022 on the subject cited above. In this connection, it is to inform you that the said building/premises were inspected by the officer concerned of this department on 26/09/2022 in presence of Smt. B.K Sandhu (Principal) to see the functioning of fire safety equipments provided in the building. During inspection, it has been observed that the said school is running at (Total Five- Block) (Two Blocks comprised of G. Floor each & Three Blocks comprised of Ground + 01 Upper Floor each).

However the following Shortcomings were observed.

1. Fire Extinguisher found empty.

In view of above Shortcomings the application for renewal of Fire safety Certificate is rejected. The occupancy of the Building/ premises in absence of requisites fire safety arrangements shall be at the risk and liabilities of the Owner/occupier. The educational authority is requested that premises should not be allowed to run till it provide all necessary fire arrangements.

Yours faithfully


(Dharampal Bhardwaj)
Dy. Chief Fire Officer
West Zone

Copy to: -

1. The Director, Directorate of Education, old secretariat, Delhi.