

C17



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

75
आज़ादी का
अमृत महोत्सव

No. F6/DFS/MS/2022/WZ/*School/621*

Dated: *30/09/2022*

To,

The Principal,
Municipal Corporation Primary Girl School,
Tikri Kalan, New Delhi-110041.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Municipal Corporation Primary Girl School, Located at Tikri Kalan, New Delhi-110041.

Sir,

This has reference to your letter no nil dated 14.07.2022 on the subject cited above. In this connection, it is to inform you that the said building have been inspected by the officer concerned of this department on 31.08.2022 in the presence of Ms. Suman Lata (Principal) to check compliance of shortcomings issued by this department vide letter no. F6/DFS/MS/2022/WZ/School/190 dated 21.04.2022

During inspection, it have been observed that the shortcomings issued by this department vide above said letter has not been rectified yet.

In view of the above shortcomings, Fire safety Certificate cannot be renewed at this stage & rejected. You are advised to rectify the above mentioned shortcomings under intimation to this department for taking further necessary action.

Yours faithfully,

(Signature)
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054

211

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001

No. F6/DFS/MS/2022/WZ/*School/190*

Dated: *21/04/2022*

To,

The Principal,
Municipal Corporation Primary Girl School,
Tikri Kalan, New Delhi-110041.

Subj:- Regarding renewal of Fire Safety Certificate in respect of Municipal Corporation Primary Girl School, Located at Tikri Kalan, New Delhi-110041.

Sir,

This has reference to your letter no nil dated nil on the subject cited above. In this connection it is to inform you that the said school building was re-inspected by the officer concerned of this department on 24.03.2022 in the presence of Ms. Suman Lata (Principal). Fire Safety arrangement such as fire extinguishers found provided.

During inspection, the following shortcomings have been observed:-

1. Two rooms constructed at terrace shall be removed.

In view of the above shortcoming, the application for renewal of Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Education Authority may take suitable necessary action as deemed fit

Yours faithfully,

[Signature]
(Dharampal Bhardwaj)
Dy. Chief Fire Officer
(West Zone)

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054