

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110001

C17

No: F.6/DFS/MS/School/2022/SZ/ 619

Dated: 30/09/2022

To,

The Principal,  
Rashtra Shakti Vidyalaya,  
Gandhi Nidhi, Hastal, Uttam Nagar,  
New Delhi-110059.

**Sub:** - Regarding issuance of Fire Safety Certificate in r/o. Rashtra Shakti Vidyalaya, Gandhi Nidhi, Hastal, Uttam Nagar, New Delhi-110059.

Sir,

This has reference to your Letter No. RSV/Director/Fire-Dept./2022/764 dated 05/09/2022 on the subject cited above. In this connection this is to inform you that officer concerned of this department inspected the school on 13/09/2022 to verify the fire safety arrangements in accordance with the Rules. At the time of inspection Smt. Shashi Tyagi (Principal) was present and it was observed that the school building is comprised of 2 blocks A block =G+3 & B block =G+2 upper floors and have following shortcomings.

1. Hose reels are provided but not functional.
2. Fire pump having 450 lpm provided but not functional.
3. Exits signage's are provided but not sufficient.

In view of above, issuance of fire safety certificate cannot be considered at this stage. You are requested to rectify the above shortcoming under the intimation to this department for further course of action.

Yours faithfully,

(Atul Garg)

Director

Delhi Fire Service

9/9/22

Copy to:-

1. Director of Education, Govt. of NCT, Old Secretariat, New Delhi-110054.