



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No. F6/DFS/MS/School/WZ/2022/ 618

Dated: 30/09/2022

To,  
The Principal,  
Sarvodaya Kanya Vidyalaya,  
Sector-20, Rohini Extn, (Pooth Kalan),  
Delhi-110086.

**Sub:** Issue of FSC in r/o Sarvodaya Kanya Vidyalaya, Sector-20, Rohini Extn, (Pooth Kalan) Delhi-110086.

Sir,


This is in reference to your letter No. 426 dated 22.07.2022 received through outdoor diary no. 4127 dated 05.08.2022 on the subject cited above. The premise was inspected by the concern nominated authority of this department on **20.09.2022**, in presence of **Sh. Kamlesh Gautam HOS** to ascertain the availability and operability of the fire prevention and fire safety measures. Your request for renewal of FSC is rejected under sub rule (3) of Rule 37 of DFS Rules-2010 due to following reason:

1. First Aid hose reel provided but not functional.
2. Terrace Fire pump with capacity 450 LPM provided but not functional.
3. The required exit signage are not provided

In this regard as stipulated in sub Rule 37 of DFS Rules, 2010 you may apply with a fresh application for renewal of fire safety certificate under sub-rule (2) on Form "J" with compliance of above shortcomings. The web links for DFS Act-2007/ Rules 2010 & Form "J" are as under:

[http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi\\_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Fire+Safety+Acts+and+Rules/http://www.delhi.gov.in/wps/wcm/connect/doi_fire/FIRE/Home/Forms)

Yours faithfully

  
(Dhrampal Bhardwaj)  
Dy.Chief Fire Officer  
Tel;-01123414250

etc

etc