

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

Dated: 27/09/2022

No. F.6/DFS/MS/Mixed/2022/SZ/ 2456
To

Mr. Vineet Mohan,
South Court Mall, A-1,
District Centre, Saket,
New Delhi- 110017

Sub: Regarding issuance of Fire Safety Certificate (FSC) in r/o M/s South Court Mall, A-1, District Centre, Saket, New Delhi- 110017


Sir,

This has reference with through Outdoor diary no 294 dated 11/04/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officers concerned of this department on 16.09.2022 in the presence Mr. Manish Kumar to verify the fire safety measures installed in the building and accordingly fire safety arrangement were tested / checked and found following observation.

1. Pressurization system not working in the staircases.
2. Door closer device & panic bar found removed from Fire Check doors.
3. Ventilation system provided but not working in Basement & upper floors.
4. MOEFA Not working in the building.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,



(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. The Jt Director (C & I) Bldg, DDA Building Section, Vikas Sadan New Delhi