GOVERNMENT OF NATIONAL CAPITAL TERRITOTY OF DELHI HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE NEW DELHI- 110001

F.6/DFS/MS/GH/2022/SZ/ No. To

Dated: ...6./...1.0./2022

The Addl. Commissioner of Police, Lic/Branch, 1st Floor, P.S Defence Colony New Delhi 110049.

Sub: Regarding renewal of FSC in r/o M/s Hotel Olive at A-406, Block-A, Road No -4, Street No 8, Mahipalpur Extn, New Delhi -37

Sir,

This has reference with MHA Portal ID 2022043008888 dated 30-04-2022 on the subject cited above. In this connection, the premises have been inspected by officer concerned of this department on 20.09.2022 in the presence of Mr. Laxman of the Guest House. During the inspection, it was observed that the Guest House is running Basement, Ground plus Three Upper Floors. The shortcomings observed are as below:

- 1. First aid hose reel provided but not functional.
- 2. MOEFA provided but not functional.
- 3. Fire Fighting pumping arrangements provided but not functional.

4. Overhead tank capacity 5,000 ltrs found empty.

5. Occupancy at 4th floor not acceptable as per clause 7.31 in UBBL 2016.

6. Further, it is requested to comply the fire safety provisions under clause 7.31 of UBBL-2016 in the building, in compliance with the notification of dated 27/05/2019 and as approved and further extended the deadline/ time limit by the Directorate of Local Bodies, UDD, GNCT of Delhi vide their letter no. F5 (189)/AD/LB/2016/5514-31 dated 31.05.2022 for compliance on or before 30/09/2022.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit. Yours faithfully,

> (SUNIL CHAWDHARY) DY. CHIEF FIRE OFFICER (SZ)

Copy to:-

1. M/s Hotel Olive at A-406, Block-A, Road No -4, Street No 8, Mahipalpur Extn, New Delhi