

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001**

No: F.6/DFS/MS/School/SZ/2022/ 625

Dated: 6/10/22

To,

The Principle,  
Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya,  
New Rajinder Nagar, New Delhi- 110060.

Sub.: - Regarding renewal of Fire Safety Certificate in r/o Rana Pratap Govt. (Sindhi) Sarvodaya Vidyalaya, New Rajinder Nagar, New Delhi- 110060.

Sir,


Please refer to your letter No. nil, dated 26.08.2022 on the subject cited above. In this connection, it is to inform you that the aforesaid school building have been inspected by the officer concerned of this department on 19.09.2022 in presence of Ms. Omlata Singh, Principal, to check the functionability of the existing fire safety arrangements in the school building.

During inspection, it has been observed that the said school building having two blocks, one block is comprised of ground plus one upper floor and one block comprised of ground plus two upper floors (each block are interconnected). Fire safety arrangements such as hose reel, terrace pump, overhead water tank, fire extinguishers, exit signage etc. found provided in the school building. However, the following shortcomings were observed:-

1. Three staircase having width of 1.50, 1.33 & 1.30 mts is provided against the requirement of two staircase having width of 1.50 mts each.
2. Continuous staircase up to terrace found not provided.

In view of the above shortcomings, 'Fire Safety Certificate' cannot be renewal at this stage. You are requested to rectify the above-mentioned shortcomings under intimation to this department.

Yours faithfully

  
(Sunil Chaudhary)  
Dy. Chief Fire Officer (SZ)  
Delhi Fire Service



Copy to: -

1. The Director of Education,  
Govt. of NCT of Delhi, Old Secretariat, New Delhi.

for information please