

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE  
Connaught Place, New Delhi-110001

No. F.6/DFS/MS/2022/BP/ *School/211*

Dated: *07/10/2022*

To

The Executive Engineer (Bldg.) HQ  
Municipal Corporation of Delhi,  
9<sup>th</sup> Floor, Civic Centre, Minto Road,  
New Delhi-110002.

**Sub: Regarding clearance of building plans in r/o addition/alteration in existing school building Summer Field School at Kailash Colony, New Delhi.**

Sir,

Please refer your online request No. 10105095 dated 28.09.2022 on the subject cited above. In this connection, this is to inform you that the building plans of proposed addn/altn. in existing school building have been scrutinized by this department from fire safety point of view and following shortcomings are observed:-

1. All around 06 meter wide motorable road with 09 m turning radius for fire tender movement is not proposed as per clause 8.2 of UBBL 2016.
2. Fire control room is not proposed as per clause 9.3.10 of UBBL 2016.
3. The direct entry to the fire pump house is not proposed as per clause 5.1.2.2 of part 4 NBC 2016.
4. Width of staircases is not as per clause 7.11.1 of UBBL 2016 and the entry to staircase is not through fire check doors as per clause 7.11(j) of UBBL 2016.
5. Details of exit door is not shown on the plans.
6. Staircases are not continuous up to terrace as per clause 7.11 (m) of UBBL 2016.
7. The fire safety and smoke control arrangements are not proposed as per NBC part 4, as per clause 9.3.9 of UBBL 2016.

In view of above, the building plans are rejected.

Yours faithfully,

*(Signature)*  
(Atul Garg)

DIRECTOR

011 - 23414000

*(Signature)*