

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F-6/DFS/MS/2022/SZ/ 2559

Dated 10/10/2022

To

The Authorized Signatory,
Ramnath House 18, Community Centre,
Yusuf Sarai, New Delhi 110049.

Sub: - Regarding issuance of fire safety certificate in r/o Ramnath House 18, Community Centre, Yusuf Sarai, New Delhi 110049.

Sir,

This has reference to your letter received through Email of dated 22/08/2022 on the subject cited above. In this connection, this is to inform you that the above mentioned premise was visited by the officer concerned of this department on 29.09.2022 in the presence of Sh. Avinash Kumar to verify the fire safety measures installed in the building. During inspection, following points were observed:

- 1 Fire check door found removed.
- 2 Automatic fire detection & alarming system not working.
- 3 MOEFA not working.
- 4 Fire fighting pumps is not on auto mode.

In view of above Shortcomings, the application for issuance Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the owner/occupier. The Licensing authority/ Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully


(ATUL GARG)
DIRECTOR

Copy to:

- 1 The Executive Engineer (Bldg.) MCD, South Zone, Building Department, Green Park, New Delhi 16