

4/18



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/Educational/SZ/2022/ 58

Dated: 06/10/2022

To

Mrs. Manju Jain (Campus Director),
Delhi Skill and Entrepreneurship University (DSEU),
Jija Bai Industrial Training Institute,
August Kranti Marg, Siri Fort Institutional Area,
Siri Fort, New Delhi-49.

Sub: - Regarding renewal of Fire Safety Certificate in r/o **Delhi Skill and Entrepreneurship University (DSEU) at Jija Bai Industrial Training Institute located at August Kranti Marg, Siri Fort Institutional Area, Siri Fort, New Delhi-49.**

Sir,

This has reference to your email dated 23.09.2022 on the subject cited above, it is informed that the said building was inspected by Assistant Divisional Officer (M. Road) from this department on 23.09.2022 in the presence of Manager and it was observed that the building is comprised of Ground + 3 upper floors (DSEU block). During the inspection the following shortcomings were observed: -

1. Alternate staircase having width not less than 1.50 mtrs should be provided.
2. Vertical opening found not sealed.
3. Hose reel found non functional.
4. Manual operated electrical fire alarm (MOEFA) found non functional.
5. Internal hydrant system found non functional.
6. Fire pump found non functional.
7. Firemen grounding switch, communication & lift signage not provided in lift.

In view of above shortcomings, the application for issuance for Fire Safety Certificate is rejected. The occupancy of the building/premises in absence of requisite fire safety arrangements shall be at the risk and liability of the management. The Statutory Authority may take suitable necessary action as deemed fit.

Yours faithfully,

(Sunil Chawdhary)
Dy. Chief Fire Officer
Delhi Fire Service

o/c [Signature] 04/10/22