



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/School/2022/NDZ/ 635

Dated 10/10/22

To,

The Manager,
K.V.M Model School,
1/7014, Shivaji park, Shahdara,
Delhi-110032.

Sub:- Regarding Issuance Fire Safety Certificate r/o K.V.M. Model School located at 1/7014, Shivaji Park, Shahdara, Delhi-110032.

Sir,

This is in reference to your letter No. nil dated 21/07/2022 on the subject cited above. In this connection, it is to inform you that the officer concerned of this department has carried out the inspection of the above mentioned School from fire safety point of view on dated 06/09/2022 in presence of Mr. Sunil Kumar, Manager. The school is running on ground plus one upper floor of the building comprised of ground plus two upper floors. Following shortcomings were observed during the time of inspection.

1. The width of staircase shall be 1.50 meter or an additional staircase of 0.75 meter shall be required.

In view of the above, the building cannot be considered for issuance of Fire Safety Certificate at this stage. Therefore, you are requested to provide the above mentioned fire safety arrangements under intimation to this office for further course of action.

Yours faithfully


(S.K. DUA)

**DY. CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy to:-

1. The Dy. Director of Education
B-Block, Yamuna Vihar,
Delhi-110053